


ELEVATION



PLAN

**SYSTEM SPECIFICATIONS:**

- MAXIMUM SERIES FLOW: 500 GPM
- MAXIMUM PRESSURE: 125 PSIG
- MAXIMUM TEMPERATURE: 150°F
- EMPTY VESSEL WEIGHT: 8,000 LBS
- VESSEL OPERATING WEIGHT: 50,000 LBS
- PIPE RACK OPERATING WEIGHT: 6,000 LBS
- SYSTEM OPERATING WEIGHT: 112,000 LBS

FOR VESSEL INFORMATION SEE DRAWING # CP-10K-8-GA-001  
 FOR P&ID SEE DRAWING # CP-10K-8-PL-001



SHEET 1 OF 2

REVISION HISTORY			
REV	DESCRIPTION	BY	DATE
2	UPDATE VESSEL TO CODE EDITION 2017	JB	11/5/2018
1	REVISE VESSEL CENTERLINE SPACING	JB	03/07/2017

PROJECT	
CP-10K-8 (SYSTEM)	
PROJ. NO.	SALES
PO. NO.	
THIS DRAWING AND DESIGN ARE THE PROPERTY OF TIGG LLC. AND SHALL NOT BE REPRODUCED IN WHOLE OR IN PART. NOR EMPLOYED FOR ANY PURPOSE OTHER THAN SPECIFICALLY PERMITTED IN WRITING BY TIGG LLC. THIS DRAWING LOANED SUBJECT TO RETURN BY DEMAND.	
DRAWN BY	JAK
DESIGN BY	JB
CHECKED BY	JB
DATE	1/22/2014
SCALE	NTS


TIGG LLC.

---

SYSTEM GENERAL ARRANGEMENT

---

CP-10K-8-GA-002



SHEET 2 OF 2

REVISION HISTORY			
REV	DESCRIPTION	BY	DATE
2	UPDATE VESSEL TO CODE EDITION 2017	JB	11/5/2018
1	REVISE VESSEL CENTERLINE SPACING	JB	03/07/2017

PROJECT	
CP-10K-8 (SYSTEM)	
PROJ. NO.	SALES
PO. NO.	
THIS DRAWING AND DESIGN ARE THE PROPERTY OF TIGG LLC. AND SHALL NOT BE REPRODUCED IN WHOLE OR IN PART. NOR EMPLOYED FOR ANY PURPOSE OTHER THAN SPECIFICALLY PERMITTED IN WRITING BY TIGG LLC. THIS DRAWING LOANED SUBJECT TO RETURN BY DEMAND.	
DRAWN BY	JAK
DESIGN BY	JB
CHECKED BY	JB
DATE	1/22/2014
SCALE	NTS

TIGG LLC.

---

SYSTEM GENERAL ARRANGEMENT

---

CP-10K-8-GA-002